CENELEC CERTIFICATION AGREEMENT
ACCORD DE CERTIFICATION DU CENELEC
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN

CCA NOTIFICATION OF TEST RESULTS

NTR/ PL2 0166

Product	**Fuse-switch disconnectors**
Tested by request of	**APATOR S.A.** **ul. Żółkiewskiego 21/29** **87-100 Toruń, Poland**
Manufactured at (name and place)	**APATOR S.A.** **ul. Żółkiewskiego 21/29** **87-100 Toruń, Poland**
Preliminary visit carried out by	**BBJ**
Rating and principal characteristics	**Rated insulation voltage U_i: 1000 V;** **Rated impulse withstand voltage $U_{imp.}$: 8 kV;** **Rated current: $I_u=I_{th}=I_e$: 160 A;** **Rated operational voltage U_e: 690 V AC, 400 V AC, 250 V DC;** **Utilization category: AC-22B, AC-23B, DC-21B, DC-22B;** **Number of poles: 3**
Trade mark (if any)	APATOR
Model/Type Ref.	**Type: RBK 00 pro** **Variations: RBK 00 pro, RBK 00 pro -M, RBK 00 pro -V,** **RBK 00 pro -W, RBK 00 pro -W-M, RBK 00 pro -W-V,** **RBK 00 pro -SG, RBK 00 pro -SG-M, RBK 00 pro -SD,** **RBK 00 pro -SD-M, RBK 00 pro -SG-V, RBK 00 pro -SD-V**
Additional information (if necessary)	**This product is covered by a certificate of the BBJ**

A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)

EN 60947-3:1999+A1:2001+A2:2005, EN 60947-1:2004

as shown in the test reports (reference No.) **LA-09.198/E**

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body which participates directly in the CENELEC Certification Agreement (CCA) of September 11th, 1973 as revised on March 29th, 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA.

STOWARZYSZENIE ELEKTRYKÓW POLSKICH SEP BIURO BADAWCZE d/s JAKOŚCI

Association of Polish Electricians
BBJ - Quality Testing Office

Warsaw; February 8, 2010

Director Janusz Okólski

Address: *ul. M. Pożaryskiego 28*
PL 0 4 -703 Warszawa
tel.: (+48 22) 812 35 10 *fax.: (+48 22) 815 65 80*
e-mail: bbj@bbj-sep..com.pl *www.bbj-sep.com.pl*